

INTERPRETATION TO THE BOILER AND PRESSURE VESSEL REGULATIONS, 2017

TSASK is issuing an interpretation to the following sub-clause of *The Boiler and Pressure Vessel Regulations, 2017*, to provide clarity on what buildings form part of an anhydrous ammonia storage and distribution plant.

Part 12 Anhydrous Ammonia Storage and Distribution Plants

Location of storage vessels

158(5) A storage vessel or a combination of storage vessels, must be located at least 500 metres away from a building, other than a building that forms part of an anhydrous ammonia storage and distribution plant.

A building will be considered a part of an anhydrous ammonia storage and distribution plant if it directly supports the sale and/or transfer of anhydrous ammonia.

Additionally, A building will be considered a part of an anhydrous ammonia storage and distribution plant if the following conditions are met:

- The building is within the direct control of the owner/operator of the anhydrous ammonia storage and distribution plant site;
- The owner/operator has both physical and administrative controls in place to manage human occupancy; and
- The site shall have and maintain a Compliance Certificate issued under Fertilizer Canada's Anhydrous Ammonia Code of Practice.

